

# LARRY KINNE

Central New York Electrical Inspection Services LLC  
7910 Rinaldo Blvd W  
Bridgeport, New York 13030  
(315) 633-0027  
ljkinne@twcnny.rr.com

## Spec's for above ground pool's

#1.

Take a # 8 bare copper solid wire from the pump too the metal frame of pool or to the seam of the pool wall.

#2.

18-24 inches out from the pool run around the entire pool with a #8 bare copper solid wire and attach to the wire in step # 1

#3.

From the skimmer take a #8 bare copper solid wire and attach to the wire in step # 2

#4.

Attach a # 8 bare copper wire in three different locations from the metal frame to the wire in step # 2 (**omit this step if no metal frame**)

#5.

All connections of the copper wire to the pool **must** have a listed connector.

#6.

The receptacle for the pump has to be at least **6 feet** away and be of the single type if within 6-10 feet of the pool. The cord on the pump can be **no longer than 3 feet**

**B.** The cord must be a **12/3 rubber cord** ( Type SJ/ SO )

**C.** The pump **must** say listed for swimming pools